



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001




No. F6/DFS/MS/WZ/2023/School/589

Dated:- 28/08/2023

FIRE SAFETY CERTIFICATE

Certified that the Bal Vidya Model School, Located at B-247, Laxmi Park, Nangloi, New Delhi-110041, comprised of Ground + 03 Upper Floors only owned/occupied by Bal Vidya Model School, was issued Fire Safety Certificate by this department Vide Letter No. F.6/DFS/MS/WZ/School/212 dated 03.07.2020. The said premise was re-inspected by the officer concerned of this department on 11.08.2023 in the presence of Sh. B.S. Dabas (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with NBC (Part-IV) and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 28/08/2023 for a period of three years in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the DFS Rules, 2010, printed below.

Issued on 28/08/2023. at New Delhi by.


(Atul Garg)
Director

Ph: No. 011-234141000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. Sh. B.S. Dabas (Manager), Bal Vidya Model School, B-247, Laxmi Park, Nangloi, New Delhi-110041.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.